

WATER ANALYSIS REPORT

Secondary Contaminants

PUBLIC WATER SUPPLY INFORMATION

TURNERS FALLS WATER DEPARTMENT PWS 1192000

LOCATION ID 10050/Well 02G Tolan Well
10053/Well 03G Hannegan Brook Well

LABORATORY ANALYTICAL INFORMATION

Con-test Analytical Laboratory Lab Cert # MA-100

Sample Dates 5/5/2016

Date Analyzed 5/16/2016

Analyte	Results mg/L	Results mg/L	MC
	Tolan Well #2	Hannegan Brook	Limit mg/L
Alkalinity-Total (CaCO3)	67	28	None
Aluminum (Al)	ND	ND	0.2
Calcium (Ca)	26	4.1	None
Chloride (Cl)	28	15	250
Color	ND	ND	15
Copper (Cu)	ND	0.027	1.3
Hardness (CaCO3)	100	24	180
Iron (Fe)	ND	0.051	0.3
Magnesium (Mg)	5.4	0.8	None
Manganese (Mn)	ND	0.0038	0.05
Odor	ND	ND	None
pH	7.8	7.6	6.5 - 8.5
Potassium (K)	2.0	14	None
Silver (Ag)	ND	ND	0.10
Sulfate (SO4)	18	8	250
TDS (total dissolved solids)	110	52	None
Turbidity	<0.30	<0.30	None
Zinc (Zn)	ND	ND	5

ND=None Detected